



MURRIETA VALLEY UNIFIED SCHOOL DISTRICT
MVUSD ASPHALT REPLACEMENT, SLURRY & RESTRIPE PROJECT

BID # 04122019
ADDENDUM # 3

Note: The following revisions and/or clarification shall be made to the Bidding Requirements and Contract Documents and all other conditions shall remain the same. The bidder shall be responsible for transmitting this information to all effected subcontractors and suppliers prior to closing the bid. The bid shall reflect these addendum changes in the Job Specifications/Site Maps for each bidder and acknowledge receipt of this Addendum in spaces provided on the Bid Form. Failure to acknowledge will subject the Bidder to disqualification.

JOB SPECIFICATIONS RFI QUESTION

LOCATION: Buchanan Elementary School and Lisa J. Mails

Question

Regarding Buchanan Es School and Lisa J Mails ES, what type of asphalt material is it calling for? ½-inch Asphalt?

Answer

½" Fine Asphalt x 4" Depth

Respectfully,

A handwritten signature in blue ink, appearing to read "David Ciabattini".

David Ciabattini, Director of Purchasing